

VOC Content Test Certificate

Thursday 13th June 2024

Supplier: Henkel Australia Pty Ltd (7 Stanton Road, Seven Hill, NSW, 2147, Australia)

Product Name: TECHNOMELT PUR 4663TW

Date Tested: 13th June 2024 (Tested by FORAY Laboratories – NATA Accreditation 1231)

Test Method: ASTM D3960 Standard Practice for Determining Volatile Organic Compound (VOC) Content of Paints and Related Coatings. ASTM D3960-05 test method is referred in accordance with the laboratory testing guidance from Green Building Council of Australia

Test Data:

| | |
|---|--|
| Specification Green Building Council of Australia Green Star Design & As Built V1.3-13.1.1B Green Star Interiors V1.3-12.1.1B | TECHNOMELT PUR 4663TW |
| Wood Flooring and Laminate Adhesives and Sealants Limit: 100 grams per litre | 5 grams per litre as VOC content per material |
| <i>We hereby certify TECHNOMELT PUR 4663TW is below the VOC Content limits of chosen category specified by Green Star Design & As Built, Green Building Council of Australia.</i> | |

Dr. Vyt Garnys
PhD, BSc(Hons) AIMM, ARACI, ISIAQ
ACA, AIRAH, FMA
Managing Director and Principal Consultant

Dr. Tuan Duong
PhD, BE (Chemical Engineer)
Senior Consultant

Travis Hale
BSc (Biotechnology)
Senior Consultant